



*Water and Wastewater Specialists  
Licensed Operations, Utility Management,  
Consulting, and Laboratory Services*

*P.O. Box 675  
Woodland Park, NJ 07424  
(973) 998-9100 Office  
(973) 998-9101 Fax*

August 13, 2025

Mr. Thomas Bolen  
Supervisor of Facilities  
Woodland Park Board of Education  
853 Mc Bride Avenue  
Woodland Park, New Jersey 07424

Re: Drinking water analysis of Lead

Dear Mr. Bolen:

As requested De Block Environmental Services worked with district staff to identify and collect samples to be analyzed for lead. Samples were collected from all potable water fountains identified by custodial staff.

All samples were collected using methods detailed by the New Jersey Department of Environmental Protection. Sampling requirements indicated a minimum period of 6 hours during which time there is no use from the sample tap or sample taps in the immediate vicinity. In order to accomplish this DES staff worked in District custodial staff to ensure no usage over the evening hours. First draw samples were collected in the morning prior to use by students and staff. This ensured the samples that would reflect the most realistic conditions on any particular school day. All samples were collected by a NJDEP licensed water operator and analyzed by an NJDEP accredited laboratory.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. However, the presence of a contaminant does not necessarily indicate that the water poses a health risk.

The Lead Action Level for drinking water is 15 ug/L or parts per billion for the 90<sup>th</sup> percentile sample within a public water supply system. As an example, if a public water supply system is required to collect 100 lead samples during a sampling event, the public system will remain in compliance if not more than 9 of the samples exceeds the Action Level. Please note that while water regulations are evolving, public water supplies are required to sample locations that are most likely to contain lead in the plumbing fixtures including properties with lead service lines and homes built prior to the ban on lead solder. In short the most at risk locations.

In the case of the Woodland Park School samples, all individual lead samples collected were less than the action levels established by the NJDEP and USEPA, **except for one sink in Beatrice Gilmore**. A “post-flush” sample was collected on August 13<sup>th</sup> as per NJDEP and US EPA regulations.

The minimum detection level (MDL) for lead in drinking water is 2 ug/L. Values below the MDL are reported as Non-Detected (ND).

Results are summarized as follows:

Memorial School:

- Eleven (11) samples were collected on August 1, 2025.
- Six (6) of the samples had Non-Detectable levels of lead.
- Five (5) of the samples had detectable level of lead between 2.03-11.1 ug/L.
- Note that the results are still below the EPA Action Level for a public water supply.

Charles Olbon School:

- Five (5) samples were collected on August 1, 2025.
- All sample results were Non Detect (ND).

School 1:

- Two (2) samples were collected on August 1, 2025.
- Kitchen sink was ND, Nurse’s sink had a detectable level of 7.10 ug/L.
- Note that the results are still below the EPA Action Level for a public water supply.

Beatrice Gilmore School:

- Eight (8) samples were collected on August 1, 2025.
- Six (6) of the samples had Non-Detectable levels of lead.
- The Nurse’s Office sink had a detectable level of 11.7ug/L. Note that the results are still below the EPA Action Level for a public water supply.
- The Reading Lab sink had a detectable level of 16.0 ug/L. **This is above the EPA action level (AL) and required a “post flush” re-sample.**

Woodland Park Early Childhood Center:

- Eight (8) samples were collected on August 1, 2025.
- All sample results were Non Detect (ND).
- Three (3) of the samples had Non-Detectable levels of lead.

- Five (5) of the samples had detectable level of lead between 2.01-5.67 ug/L.
- Note that the results are still below the EPA Action Level for a public water supply.

Copies of the Laboratory Reports, Chains of Custody and spreadsheet detailing the results for each sample location are included for your review.

We would recommend that as a matter of routine all drinking water fountains be run each morning, prior to the start of school, until the water runs cold. This will serve to flush any warm water that may have remained stagnant in the water pipes overnight, thus reducing to the lowest possible level any residual contaminants. Additional information is available on the EPA website at <https://www.epa.gov/your-drinking-water/basic-information-about-lead-drinking-water>

If you have any questions or concerns I can be reached at 973-998-9100.

Very truly yours,

Robert J. De Block  
*Executive V.P.*

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

## CERTIFICATE OF ANALYSIS

**Christina Goldstein**

**DeBlock Environmental Services, LLC  
16 Hugo Avenue, PO Box 675  
Woodland Park, NJ 07424**

Project Name and Number: **Charles Olbon**  
Workorder: **25H0108**  
Purchase Order:

August 08, 2025

This report relates only to the sample(s) as received by the laboratory on August 1, 2025. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your Pace Analytical Services, LLC-Fairfield project coordinator.

Note: This cover page is included as part of the Analytical Report and must be retained as a permanent record thereof.



Sherry A. Flyte For Victor G. Cervantes, Project  
Manager

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

Lab ID: 25H0108-01

Matrix: Drinking Water

Date Collected: 08/01/2025 07:20

Sample ID: Field Blank

Date Received: 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:54	08/07/2025 16:54	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0108-02  
**Sample ID:** Teacher's Lounge Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:22

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:58	08/07/2025 16:58	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

Lab ID: 25H0108-03

Matrix: Drinking Water

Date Collected: 08/01/2025 07:25

Sample ID: Bottle Filler 1

Date Received: 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:02	08/07/2025 17:02	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0108-04  
**Sample ID:** Bottle Filler 2

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:27

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:06	08/07/2025 17:06	1



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0108-05  
**Sample ID:** Nurse's Office Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:29  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:11	08/07/2025 17:11	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0108-06  
**Sample ID:** Kitchen Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:31

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:23	08/07/2025 17:23	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

#### Qualifiers

U Compound not detected

---

#### Abbreviations

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTLC	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Laboratory Certification List for this report.**

Laboratory	Certification			
	NJ	NY	PA	CT
Pace Analytical Services, LLC Ewing 812 Silvia Street Ewing, NJ 08628	11005	12046	68-05417	
Pace Analytical Services, LLC-Fairfield 1275 Bloomfield Ave, Ste 37D Fairfield, NJ 07004	07010	11634	68-02903	



25H0108

Page 1 of 1



### Sample Condition Upon Receipt Form (SCUR)

Affix Sample Label Here

Date and Initials of person:

Examining contents: 8/1 M

Label: 8/1 MC

Deliver to location: \_\_\_\_\_

pH: 8/1 AR

Thermometer Used: 7265

Date: 8/1/25

Time: 1435

Initials: AR

State of Origin: NJ

Cooler #1 Temp. °C 15.7 (Visual) 0.0 (Correction Factor) 15.7 (Actual)

☐ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace

☐ Other \_\_\_\_\_

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other \_\_\_\_\_

Tracking # \_\_\_\_\_

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No

Seals intact: ☐ Yes ☒ No

Ice: Wet Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None

☐ Other \_\_\_\_\_

Samples were collected by Pace employee

☐ Yes

☒ No

☐ N/A

#### Comments:

Chain of Custody Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature on COC	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sampler Name and Signature on COC	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Additional Login Comments:

#### Client notification/ Resolution

Person Contacted: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments/Resolution: \_\_\_\_\_

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

## CERTIFICATE OF ANALYSIS

**Christina Goldstein**

**DeBlock Environmental Services, LLC  
16 Hugo Avenue, PO Box 675  
Woodland Park, NJ 07424**

Project Name and Number: **Beatrice Gilmore**

Workorder: **25H0107**

Purchase Order:

August 11, 2025

This report relates only to the sample(s) as received by the laboratory on August 1, 2025. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your Pace Analytical Services, LLC-Fairfield project coordinator.

Note: This cover page is included as part of the Analytical Report and must be retained as a permanent record thereof.



Victor G. Cervantes, Project Manager

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

Lab ID: 25H0107-01

Matrix: Drinking Water

Date Collected: 08/01/2025 07:00

Sample ID: Field Blank

Date Received: 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:15	08/07/2025 16:15	1



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0107-02  
**Sample ID:** Main Hall Bottle Filler

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:02  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/08/2025 11:43	08/08/2025 11:43	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0107-03  
**Sample ID:** Nurse's Office Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:03

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.0117		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:19	08/07/2025 16:19	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0107-04

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:06

**Sample ID:** Kitchen Sink

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:32	08/07/2025 16:32	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0107-05  
**Sample ID:** Library Office Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:07

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 15:07	08/07/2025 15:07	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0107-06 **Matrix:** Drinking Water **Date Collected:** 08/01/2025 07:09  
**Sample ID:** FL2 Storage Room Bottle Filler **Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:37	08/07/2025 16:37	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0107-07  
**Sample ID:** Reading Lab Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:10  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.0160		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:41	08/07/2025 16:41	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0107-08  
**Sample ID:** 200 Hall Bottle Filler

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:12

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:45	08/07/2025 16:45	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0107-09  
**Sample ID:** Teacher's Lounge Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:13  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:49	08/07/2025 16:49	1



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

#### Qualifiers

U Compound not detected

---

#### Abbreviations

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTLC	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

**Pace Analytical Services, LLC-Fairfield**  
**1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004**  
**(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)**

**Laboratory Certification List for this report.**

Laboratory	Certification				
	NJ	NY	PA	CT	
Pace Analytical Services, LLC Ewing 812 Silvia Street Ewing, NJ 08628	11005	12046	68-05417		
Pace Analytical Services, LLC-Fairfield 1275 Bloomfield Ave, Ste 37D Fairfield, NJ 07004	07010	11634	68-02903		



25H0107

Sample Condition Upon Receipt Form (SCUR)



Affix Sample Label Here

Date and Initials of person:

Examining contents: 8/1/24

Label: 8/1/24

Deliver to location: \_\_\_\_\_

pH: 8.1

Thermometer Used: 71206

Date: 8/1/24

Time: 1435

Initials: AM

State of Origin: NJ

Cooler #1 Temp. °C 25.7 (Visual) 0.0 (Correction Factor) 15.7 (Actual)

☐ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace

☐ Other \_\_\_\_\_

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other \_\_\_\_\_

Tracking # \_\_\_\_\_

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No

Seals intact: ☐ Yes ☒ No

Ice: Wet Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None

☐ Other \_\_\_\_\_

Samples were collected by Pace employee

☐ Yes

☒ No

☐ N/A

Comments:

Chain of Custody Present	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sampler Name and Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments/Resolution: \_\_\_\_\_

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

## CERTIFICATE OF ANALYSIS

**Christina Goldstein**  
**DeBlock Environmental Services, LLC**  
**16 Hugo Avenue, PO Box 675**  
**Woodland Park, NJ 07424**

Project Name and Number: **Woodland Park ECC**  
Workorder: **25H0109**  
Purchase Order:


August 11, 2025

This report relates only to the sample(s) as received by the laboratory on August 1, 2025. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your Pace Analytical Services, LLC-Fairfield project coordinator.

Note: This cover page is included as part of the Analytical Report and must be retained as a permanent record thereof.

  
\_\_\_\_\_  
Victor G. Cervantes, Project Manager

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

Lab ID: 25H0109-01

Matrix: Drinking Water

Date Collected: 08/01/2025 07:40

Sample ID: Field Blank

Date Received: 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:28	08/07/2025 17:28	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0109-02  
**Sample ID:** Teacher's Lounge

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:43

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:32	08/07/2025 17:32	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0109-03 **Matrix:** Drinking Water **Date Collected:** 08/01/2025 07:45  
**Sample ID:** Building 1 Room 1 **Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00290		mg/L	0.000492	0.00200	EPA 200.8	08/08/2025 11:47	08/08/2025 11:47	1



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0109-04  
**Sample ID:** Kitchen Double Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:48

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:36	08/07/2025 17:36	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0109-05  
**Sample ID:** Kitchen Sink 1

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:47

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00492		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:40	08/07/2025 17:40	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0109-06 **Matrix:** Drinking Water **Date Collected:** 08/01/2025 07:50  
**Sample ID:** Building 2 Room 4 **Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00201		mg/L	0.000492	0.00200	EPA 200.8	08/08/2025 11:26	08/08/2025 11:26	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

Lab ID: 25H0109-07  
Sample ID: Building 2 Nurse

Matrix: Drinking Water

Date Collected: 08/01/2025 07:52

Date Received: 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:45	08/07/2025 17:45	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0109-08  
**Sample ID:** Building 2 Room 3

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:53

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00567		mg/L	0.000492	0.00200	EPA 200.8	08/08/2025 11:51	08/08/2025 11:51	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0109-09  
**Sample ID:** Building 1 Room 2

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 07:55  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00544		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:49	08/07/2025 17:49	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

### Qualifiers

U Compound not detected

---

### Abbreviations

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTLC	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Laboratory Certification List for this report.**

Laboratory	Certification				
	NJ	NY	PA	CT	
Pace Analytical Services, LLC Ewing 812 Silvia Street Ewing, NJ 08628	11005	12046	68-05417		
Pace Analytical Services, LLC-Fairfield 1275 Bloomfield Ave, Ste 37D Fairfield, NJ 07004	07010	11634	68-02903		





Sample Condition Upon Receipt Form (SCUR)

25H0109



Affix Sample Label Here

Date and Initials of person:  
Examining contents: 8/1/26  
Label: 8/1 AR  
Deliver to location: \_\_\_\_\_  
pH: 8.1 AR

Page 14 of 14

Thermometer Used: TRC6

Date: 8/1/26

Time: 1435

Initials: AR

State of Origin: NJ

Cooler #1 Temp. °C 15.7 (Visual) 0.0 (Correction Factor) 15.7 (Actual)

☐ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace

☐ Other \_\_\_\_\_

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other \_\_\_\_\_

Tracking # \_\_\_\_\_

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No

Seals intact: ☐ Yes ☒ No

Ice: Wet Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None

☐ Other \_\_\_\_\_

Samples were collected by Pace employee

☐ Yes

☒ No

☐ N/A

Comments:

Chain of Custody Present	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sampler Name and Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments/Resolution: \_\_\_\_\_

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

## CERTIFICATE OF ANALYSIS

**Christina Goldstein**

**DeBlock Environmental Services, LLC  
16 Hugo Avenue, PO Box 675  
Woodland Park, NJ 07424**

Project Name and Number: **School 1**  
Workorder: **25H0110**  
Purchase Order:

August 08, 2025

This report relates only to the sample(s) as received by the laboratory on August 1, 2025. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your Pace Analytical Services, LLC-Fairfield project coordinator.

Note: This cover page is included as part of the Analytical Report and must be retained as a permanent record thereof.



Sherry A. Flyte For Victor G. Cervantes, Project Manager

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

Lab ID: 25H0110-01

Matrix: Drinking Water

Date Collected: 08/01/2025 08:11

Sample ID: Field Blank

Date Received: 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:53	08/07/2025 17:53	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0110-02  
**Sample ID:** Nurse's Office Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 08:15  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00710		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 17:57	08/07/2025 17:57	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0110-03  
**Sample ID:** Kitchen Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 08:17

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 18:02	08/07/2025 18:02	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

### Qualifiers

U Compound not detected

---

### Abbreviations

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTLC	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Laboratory Certification List for this report.**

Laboratory	Certification			
	NJ	NY	PA	CT
Pace Analytical Services, LLC Ewing 812 Silvia Street Ewing, NJ 08628	11005	12046	68-05417	
Pace Analytical Services, LLC-Fairfield 1275 Bloomfield Ave, Ste 37D Fairfield, NJ 07004	07010	11634	68-02903	





25H0110

Page 8 of 8

### Sample Condition Upon Receipt Form (SCUR)



Affix Sample Label Here

Date and Initials of person:

Examining contents: 8/1/25

Label: 811 AN

Deliver to location: \_\_\_\_\_

pH: 8.1

Thermometer Used: T1206

Date: 8/1/25

Time: 1435

Initials: AN

State of Origin: NJ

Cooler #1 Temp. °C 15.7 (Visual) 0.0 (Correction Factor) 15.7 (Actual)

☐ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace

☐ Other \_\_\_\_\_

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other \_\_\_\_\_

Tracking # \_\_\_\_\_

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No

Seals intact: ☐ Yes ☒ No

Ice: Wet Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None

☐ Other \_\_\_\_\_

Samples were collected by Pace employee

☐ Yes

☒ No

☐ N/A

#### Comments:

Chain of Custody Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature on COC	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sampler Name and Signature on COC	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Trip Blank Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	

Additional Login Comments:

#### Client notification/ Resolution

Person Contacted: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments/Resolution: \_\_\_\_\_

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

## CERTIFICATE OF ANALYSIS

**Christina Goldstein**  
**DeBlock Environmental Services, LLC**  
**16 Hugo Avenue, PO Box 675**  
**Woodland Park, NJ 07424**

Project Name and Number: **Memorial**

Workorder: **25H0106**

Purchase Order:

August 08, 2025

This report relates only to the sample(s) as received by the laboratory on August 1, 2025. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your Pace Analytical Services, LLC-Fairfield project coordinator.

Note: This cover page is included as part of the Analytical Report and must be retained as a permanent record thereof.



Sherry A. Flyte For Victor G. Cervantes, Project  
Manager

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-01

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 06:35

**Sample ID:** Field Blank

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/06/2025 19:40	08/06/2025 19:40	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-02      **Matrix:** Drinking Water      **Date Collected:** 08/01/2025 06:36  
**Sample ID:** Growing Minds Sink      **Date Received:** 08/01/2025 14:35

Total Metals - Pace Analytical Services, LLC-Fairfield									
Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.0103		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 15:24	08/07/2025 15:24	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-03  
**Sample ID:** Gym Hall Bottle Filler

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 06:38

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 15:28	08/07/2025 15:28	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

Lab ID: 25H0106-04  
Sample ID: Nurse's Office Sink

Matrix: Drinking Water

Date Collected: 08/01/2025 06:41

Date Received: 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.0111		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 15:41	08/07/2025 15:41	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-05  
**Sample ID:** Teacher's Lounge

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 06:44  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00203		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 15:45	08/07/2025 15:45	1



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-06  
**Sample ID:** Kitchen Sink 1

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 06:47

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 15:50	08/07/2025 15:50	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-07 **Matrix:** Drinking Water **Date Collected:** 08/01/2025 06:49  
**Sample ID:** Kitchen Sink 2 **Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00299		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 15:54	08/07/2025 15:54	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-08  
**Sample ID:** Caf. Hall Bottle Filler

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 06:46  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 14:50	08/07/2025 14:50	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-09  
**Sample ID:** Coffee Feed Sink

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 06:50  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 15:58	08/07/2025 15:58	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-10  
**Sample ID:** Kitchen Double Sink Left

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 06:51

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00229		mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:02	08/07/2025 16:02	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-11  
**Sample ID:** Kitchen Double Sink Right

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 06:52

**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:07	08/07/2025 16:07	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25H0106-12  
**Sample ID:** Spinner Hall Bottle Filler

**Matrix:** Drinking Water

**Date Collected:** 08/01/2025 06:54  
**Date Received:** 08/01/2025 14:35

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	08/07/2025 16:11	08/07/2025 16:11	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

### Qualifiers

U Compound not detected

### Abbreviations

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTLC	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Laboratory Certification List for this report.**

Laboratory	Certification				
	NJ	NY	PA	CT	
Pace Analytical Services, LLC Ewing 812 Silvia Street Ewing, NJ 08628	11005	12046	68-05417		
Pace Analytical Services, LLC-Fairfield 1275 Bloomfield Ave, Ste 37D Fairfield, NJ 07004	07010	11634	68-02903		

DeBlock Environmental Services, LLC  
Memorial

7/10/2014, 8:00 AM - 8:05 AM

©. I hereby declare a certificate with this chain of custody consistent with acknowledgment and acceptance of the Pace® Terms and Conditions found at <https://www.paceelabs.com/resource-library/resource/pace-terms-and-conditions/>



25H0106

Sample Condition Upon Receipt Form (SCUR)



Affix Sample Label Here

Date and Initials of person:

Examining contents: 8/1 AR

Label: 8/1 AR

Deliver to location: \_\_\_\_\_

pH: 8.1 AR

Thermometer Used: TROC

Date: 8/1/25

Time: 1435

Initials: AR

State of Origin: NJ

Cooler #1 Temp. °C 15.7 (Visual) 0.0 (Correction Factor) 15.7 (Actual)

☐ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace

☐ Other \_\_\_\_\_

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other \_\_\_\_\_

Tracking # \_\_\_\_\_

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No

Seals intact: ☐ Yes ☒ No

Ice: Wet Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None

☐ Other \_\_\_\_\_

Samples were collected by Pace employee

☐ Yes

☒ No

☐ N/A

Comments:

Chain of Custody Present	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sampler Name and Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments/Resolution: \_\_\_\_\_